



Product Service

Attestation of Conformity

No. N8A 103237 0012 Rev. 05

Holder of Attestation: Hanersun Technology Co., Ltd.

10F, B4 Block
No.19, Suyuan Avenue, Jiangning District
211100 Nanjing
PEOPLE'S REPUBLIC OF CHINA

Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062122701-05

Date, 2023-11-06

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

Attestation of Conformity

No. N8A 103237 0012 Rev. 05

Model(s):

HN21-66HTxxxW, xxx=635-670 in step of 5
 HN21-60HTxxxW, xxx=580-610 in step of 5
 HN21N-66HTxxxW, xxx=670-700 in step of 5
 HN21N-60HTxxxW, xxx=610-635 in step of 5
 HN18-72HTxxxW, xxx=525-555 in step of 5
 HN18-66HTxxxW, xxx=485-510 in step of 5
 HN18-60HTxxxW, xxx=440-460 in step of 5
 HN18-54HTxxxW, xxx=390-415 in step of 5
 HN18N-72HTxxxW, xxx=555-590 in step of 5
 HN18N-66HTxxxW, xxx=510-540 in step of 5
 HN18N-60HTxxxW, xxx=460-490 in step of 5
 HN18N-54HTxxxW, xxx=415-440 in step of 5
 HN17-72HTxxxW, xxx=425-460 in step of 5
 HN17-60HTxxxW, xxx=355-385 in step of 5
 HN18-60HTxxxW-FL, xxx=440-460 in step of 5
 HN18-54HTxxxW-FL, xxx=390-415 in step of 5
 HN18N-60HTxxxW-FL, xxx=460-490 in step of 5
 HN18N-54HTxxxW-FL, xxx=415-440 in step of 5
 xxx is standing for rated output power at STC

Parameters:

Construction: Framed & Frameless,
 with Junction box,
 Cable and Connectors.
 Test Laboratory: Yangzhou Opto-Electrical
 Products Testing Institute
 No. 10 West Kaifa Road, Yangzhou
 225009 Jiangsu, P. R. China
 Safety Class: Class II
 Maximum System Voltage: 1500 V DC
 Fire Safety Class: Class C according to UL790.

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

